

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193102
Address: 1824 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, May 11, 2020

Corrective Action Required:

1	Miscellaneous Correction	- BLOCK SHEATHING BREAK ABOVE SINGLE CAR GARAGE - - OPEN PORCH LID TO EXPOSE HANGERS - - PROVIDE 800 LB HOLD DOWNS EC#2 PER PLAN - - PROVIDE PFH PORTAL FRAME GARAGE DOOR PER PLAN - - NAIL SHEATHING AT FRONT PORCH WITH 8D NAILS PER PLAN
---	--------------------------	---

Comments: