

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191159
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	Robb Popp	Partial	Tuesday, May 12, 2020

Partial Correction:

1 Misc

NO ISSUES FOUND ON EQUIPOTENTIAL BONDING AT:
POOL BOTTOM SLAB - LEADS STUBBED UP ABOVE POUR LINE; WEST POOL WALL FROM NORTH ALONG WIDTH OF SURGE TANK; EAST POOL WALL NORTH 25'; WEST POOL WALL; SOUTH EXTREMITY OF POOL SLAB REINFORCING & PLUMBING CASTINGS-
5/1/20 LIFT, LADDER, SHADE STRUCTURE, DECK

Corrective Action Required:

2 Misc

THE FOLLOWING AREAS ARE APPROVED:
EAST SIDE OF POOL DECK NEXT TO BUILDING WORKING SOUTH EAST.
SOUTHEAST CORNER OF POOL ENTRANCE
BONDING FROM POOL AND SOUTHEAST CORNER LIGHT POLE
BONDING OF POOL LOOP AND 2 SHADE POLES

Comments: