

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192156
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Tuesday, May 12, 2020

Corrective Action Required:	
1 THE FOLLOWING AREAS ARE APPROVED	ALL TRADES MEP'S WALL SECTIONS: PENDING APPROVAL 1 LINE D-H

PENDING FOR FRIDAY 5/12
AREA 11 LINE D-H

Corrective Action Required:	
2 Misc	install pipe insulation and boca plates as required in wall. RESCHEDULE FOR 5/13

Comments: