

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191681  
Address: 560 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Failed	Tuesday, May 12, 2020

Corrective Action Required:

1	Misc	support all MC cable, install 2 support wires per light fixture throughout. support all DWV 48"o.c.and condensate line to front office.
---	------	--

reset for wednesday 5/13

**Comments:**