

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191899
Address: 1821 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Tuesday, May 12, 2020

Corrective Action Required:

2	Miscellaneous Correction	-AS GRADED PLOT PLAN REQUIRED -PROVIDE EROSION CONTROL OR SOD -FINAL GRADING -MIN. 36" DISCHARGE FROM FOUNDATION FOR DOWNSPOUTS AND SUMP REQUIRED -INSTALL SECURITY SCREWS BACK DOOR -SELF CLOSING HINGES AT GARAGE DOOR -CHECK ALL EXTERIOR GFCI OUTLETS
---	--------------------------	---

Comments: