

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193576
Address: 2927 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, May 12, 2020

Corrective Action Required:

1	Misc	- Fire stopping at floor and ceiling penetrations, flue chase/heat chase 1st floor - UNABLE TO INSPECT AS HOUSE HAS BEEN INSULATED AND MAJORITY OF WALLS HAD DRYWALL INSTALLED DURING TIME OF INSPECTION
		- (3) 2x10 floor joists flush between B piers in basement at stairs
2	Misc	- Engineer letter for egress header received. RES Engineering, Bradley Huxol 5/8/20

Comments: