

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191899
Address: 1821 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Miscellaneous Correction	-AS GRADED PLOT PLAN REQUIRED -FINAL GRADING SOD -MIN. 36" DISCHARGE FROM FOUNDATION FOR DOWNSPOUTS AND SUMP REQUIRED - RE ESTABLISH EROSION CONTROL AT FRONT OF LOT WITH SILT FENCE OR PLACE SOD TO OBTAIN TCO. MAINTAIN EROSION CONTROL UNTIL SOD IS PLACED. -
---	--------------------------	---

Comments: