

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193451
Address: 1405 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Michael Harkins	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Misc	- PROVIDE BONDING GAS LINE - - PROVIDE MIN 10 PSI & GUAGE FOR GAS TEST - - SECURE & SEAL GAS LINE AT FIREPLACE - - CONNECT GAS LINE TO FIREPLACE -
---	------	---

Comments: