

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193451  
Address: 1405 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Misc	- ANCHOR BOLTS GARAGE - - VENT BATH EXHAUST TO EXTERIOR WITH METALLIC TAPE - - SEAL DEAD SPACE AT MUD ROOM - - SEAL FLOOR AT MUD ROOM BATH - - SOLID SECURITY BLOCKING PATIO DOOR - - SEAL HVAC CHASES GREAT ROOM - - SEAL HVAC CHASE LAUNDRY ROOM - - SEAL UPWARD PENETRATIONS 2ND STORY TOP & BOTTOM PLATE - - - PROVIDE DOUBLE JOIST AT FURNACE PER PLAN - - -
---	------	--

Comments: