

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193631
Address: 3020 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Misc	-PROVIDE EFFECTIVE EROSION CONTROL BEFORE ANY FURTHER INSPECTIONS - PROVIDE TRUSS HANGERS PER TRUSS LAYOUT, ABOVE STAIRWAY & MASTER - -PROVIDE 3 1.2 SCH 40 COLUMN GARAGE PER PLAN - - PROVIDE (2) STHD14R AT STAIRWAY PER PLAN - - BASEMENT TIGHTEN ALL ANCHOR BOLTS THAT SHALL BE IN MIDDLE 1/3 OF WIDTH OF PLATE - - COMPLETE FIREPLACE VENT - -PROVIDE FLASHING ABOVE HORIZONTAL TRIM GARAGE DOORS - ADDRESS HEADERS ABOVE BASEMENT WINDOWS -
---	------	--

Comments: