

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193319
Address: 4032 SW BENZIGER DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Misc	- PROVIDE CITY STAMPED ENGINEERED FLOOR JOIST LAYOUT - - PROVIDE PFH PORTAL FRAME GARAGE DOOR PER PLAN - - PROVIDE BOCA PLATE 1ST FLOOR BATH - -SEAL UPWARD PENETRATIONS AT FIRE PLACE - - FURR OUT HVAC CLOSET BED # 2
---	------	---

Comments: