

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193634
Address: 3009 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Misc	- PROVIDE (2) 2 x 10 HEADER EGRESS WINDOW - -PROVIDE STUD SHOES MASTER VANITY - - PROVIDE (2) STHD14R STRAPS AT STAIRWAY PORCH - -PROVIDE HANGERS PER TRUSS LAYOUT SCHEDULE GARAGE, OPEN UP PATIO & PORCH TO CHECK -
---	------	--

Comments: