

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 64081
2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Backflow Preventer and Vault	Ronald Paynter	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Misc	Fire line back flow vault is missing its required floor and drain per detail #5 on page C7.2 per the plans. RP 5-13-20
---	------	--

Comments: