

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193576
Address: 2927 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Misc	- (3) 2x10 floor joists flush between B piers in basement at stairs
Informational:		
2	Misc	- Engineer letter for egress window header received. RES Engineering, Bradley Huxol 5/8/20

Comments: