

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200721  
Address: 2710 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Wednesday, May 13, 2020

Corrective Action Required:

1	Misc	-SWINGING DOORS SERVING SPACES WITH OCCUPANT LOAD OF 50 OR MORE SHALL HAVE: PANIC OR FIRE EXIT HARDWARE; OR LOCKING DEVICES IN ACCORDANCE WITH SECTION 1010.1.9.4, ITEM 2. THE LOCKING DEVICE MUST BE READILY DISTINGUISHABLE AS LOCKED, A READILY VISIBLE SIGN INSTALLED ON THE EGRESS SIDE STATING: "THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED". THE SIGN MUST BE IN LETTERS 1" HIGH -INSTALL FLUSH LEVER ON THE APPROACH SIDE OF THE TOILET -PROVIDE GFCI PROTECTION FOR THE DRINKING FOUNTAIN OUTLET -FASTEN THE ELECTRICAL PANEL COVER TO ENCLOSURE
---	------	--

\*\*OK TO STOCK SPACE

**Comments:**