

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192495

Address: 2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Passed	Thursday, May 14, 2020

Informational:

1 Misc

-Med gas wall must be rated one hour with exposure on both sides

****OK TO ROCK MED GAS RM WALLS ON BOTH SIDES. I WILL NEED A LADDER TO VERIFY. THE 2X4 STUD WALL MUST BE ROCKED ON BOTH SIDES WITH 5/8" TYPE X GYP**

Comments: