

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193524
Address: 1512 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, May 14, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Maintain gravel filter at drive- Seal all upward penetrations at top plate- PFH per plans in garage- Strap top plates N garage wall and above fireplace- Seal penetrations in flue chase 1st floor- Protect and secure PEX at showers- Fire stopping at tub traps, showers- Protect electrical panel from PEX water line above |
|---|------|---|

Comments: