

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20200789
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Pipe	Ronald Paynter	Partial	Thursday, May 14, 2020

Informational:
1 Misc Marty with Rainbow Construction started working on roof drain #2 today. RP 5-13-20

Informational:
2 Misc Marty's crew has continued working on drain line #2. Made some field changes to 45's instead of 90's where it wraps around the building. Also talked with Mark Goracke from A.L. Huber concerning the severe slope to the inlets. He has contacted Designer Matt Schlitt about raising one of them. He believes the other one won't be that severe. RP 5-14-20

Comments: