



May 5, 2020


Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Revision of main floor framing for Lot # 68 Hawthorne Ridge – 2927 SW Arbor Tree Dr. Lee's Summit, MO 64082 Permit # PRRES20193064

This letter addresses the revision to the main floor framing for Lot# 68 Hawthorne Ridge.

The revisions shall be as follows:

- (2) #2 2x10 Douglas Fir Larch flush spanning approximately 15'8" as shown below.



Sincerely,

A handwritten signature in blue ink, appearing to read "Bradley Huxol".

Bradley Huxol, PE

