

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

December 20, 2019

CENTRIC CONSTRUCTION GROUP
520 W PENNWAY STE 100
KANSAS CITY, MO 64108

Permit No: PRCOM20192520
Project Title: ARISTOCRAT PRE-OWNED AUTOMOTIVE DEALERSHIP
Project Address: 704 SE OLDHAM CT, LEES SUMMIT, MO 64081
Parcel Number: 61500043300000000
Location: OLDHAM EAST BUSINESS PARK LOT 2
Type of Work: NEW COMMERCIAL
Occupancy Group: BUSINESS
Description: NEW BUILDING FOR CAR DEALERSHIP WITH SINGLE CAR WASH BAY AND EQUIPMENT
MEZZANINE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

7. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.
(Verified At Inspection)

6. 2018 IFC 907.3.1 Duct smoke detectors. Smoke detectors installed in ducts shall be listed for the air velocity, temperature and humidity present in the duct. Duct smoke detectors shall be connected to the building's fire alarm control unit when a fire alarm system is required by Section 907.2. Activation of a duct smoke detector shall initiate a visible and audible supervisory signal at a constantly attended location and shall perform the intended fire safety function in accordance with this code and the International Mechanical Code. Duct smoke detectors shall not be used as a substitute for required open area detection.
(Verified At Inspection)

4. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.
(Verified At Inspection)

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).
(Verified At Inspection)

Building Plan Review

Reviewed By: Joe Frogge

Approved

2. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.
10/10/19 - Acknowledged in letter

5. 2018 IPC 708.1 Cleanouts Required. Cleanouts shall be provided for drainage piping in accordance with Sections 708.1.1 through 708.1.11.
2018 IPC 708.1.3 Building drain and building sewer junction. The junction of the building drain and the building sewer shall be served by a cleanout that is located at the junction or within 10 feet of the developed length of piping upstream of the junction. For the requirements

Action required: Provide cleanouts near where sewer piping leaves foundation.
10/10/19 - Civil drawing referenced in letter not found in submittal. To be field verified.

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

2. Lee's Summit Code of Ordinance, Section7-130.4 - Business License. (excerpt)
No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.
10/10/19 - Acknowledged in letter

Licensed Contractors

Reviewed By: Joe Frogge

Approved

1. Lee's Summit Code of Ordinance, Section7-130.4 - Business License. (excerpt)
No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.
10/10/19 - Acknowledged in letter

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.