

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193026
Address: 141 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Friday, May 15, 2020

Corrective Action Required:

1	Misc	- provide (2) 3" screws in each exterior door hinge basement door - - raise handrail exterior stairs to meet code & return end to wall - - provide outlet within 25' of exterior HVAC equipment (not connected to load side of the equipment disconnect)
---	------	--

Comments: