

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192818
Address: 4064 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, May 15, 2020

Corrective Action Required:

1	Misc	-GARAGE PORTAL WALLS FRAMING ONLY-OK
---	------	--------------------------------------

****GO AHEAD AND INSULATE THE CANTILEVERED JOISTS. I WILL INSPECT THE SOLIDBLOCKING AT ALL-ROUGH**

Comments: