

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20181829  
Address: 1325 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Friday, May 15, 2020

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | -Lawn irrigation permit required                           |
|   |      | -As-graded plot plan is required                           |
|   |      | -Locate sewer tracer wire and install the sewer tracer box |
|   |      | **Sewer tracer wire, not gas tracer wire.                  |
|   |      | -The pantry/garage door must self-close                    |
|   |      | -Locate and make accessible the sewer clean out            |

**Comments:**