

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170411

Address: 3580 SW HOLLYWOOD DR, Unit:8, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Monday, May 18, 2020

Corrective Action Required:

1	LOWER LEVEL	- FIRE BLOCK FURR OUT FOUNDATION WALL EVERY 10' - - 00 FIRE CAULK SEC CABLE TOP PLATE SECURE SEC CABLES - - 02 INSULATE TUB TRAP CEILING, FIRE CAULK DWV TOP PLATE, ADDRESS BORE @ BATH VANITY - - 10 SECURE SEC CABLES, PROVIDE STUD SHOE OVERSIZED BORE KITCHEN/BEDROON -
---	-------------	--

Comments: