

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193524
Address: 1512 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Monday, May 18, 2020

Corrective Action Required:

1	Misc	- Seal all upward penetrations at top plate-master bath WC - PFH per plans in garage - Strap top plates above fireplace - Seal penetrations in flue chase 1st floor - Protect and secure PEX at showers - Fire stopping at tub traps, showers - Protect electrical panel from PEX water line above
---	------	--

Comments: