

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201094
Address: 4408 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Passed	Monday, May 18, 2020

Informational:
1 Misc (1) PIER PAD 26 X 26 W/ 5 # 4 EACH WAY
DETAIL H PER PLAN 16" x 36" PIER W/ (4) VERTICAL #4

Comments: