

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172521
Address: 241 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Michael Harkins	Failed	Monday, May 18, 2020

Corrective Action Required:
1 LOWER LEVEL SOUTH END
- PROVIDE ANCHOR BOLTS THROUGHOUT -
- CHECK FLASHING UNDER MISSING WINDOWS -

Corrective Action Required:
2 FIRST FLOOR SOUTH END -
- PROVIDE ANCHOR BOLTS THROUGHOUT -
- CHECK FLASHING MISSING WINDOWS -

Corrective Action Required:
3 SECOND FLOOR SOUTH END
- 307 provide roof boots, support SEC cables -
- 305 h 2.5s deck, roof boots -
- CHECK FLASHING UNDER MISSING WINDOWS -

Comments: