

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20191899
Address: 1821 SW BLACKSTONE PL, LEES SUMMIT, MO 64082
Inspected On: Monday, May 18, 2020
Inspected By: Mark Harding
Expiration Date: 6/1/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Temporary C of O	Monday, May 18, 2020

Corrective Action Required:

1	Miscellaneous Correction	-AS GRADED PLOT PLAN REQUIRED -FINAL GRADING SOD -MIN. 36" DISCHARGE FROM FOUNDATION FOR DOWNSPOUT AND SUMP REQUIRED
	--	TCO ISSUED FOR 2 WEEKS FOR AS GRADED PLOT PLAN SUBMITTAL AND REVIEW./