

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193524  
Address: 1512 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector: | Outcome: | Date:                 |
|-------------------------------------------|------------|----------|-----------------------|
| <b>All Rough Inspection - Residential</b> | Robb Popp  | Failed   | Tuesday, May 19, 2020 |

Corrective Action Required:

|   |      |                                                            |
|---|------|------------------------------------------------------------|
| 1 | Misc | - Seal all upward penetrations at top plate-master bath WC |
|---|------|------------------------------------------------------------|

**Comments:**