

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200874  
Address: 1805 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Michael Harkins Residential</b>		Failed	Tuesday, May 19, 2020

Corrective Action Required:

1	Misc	- PROVIDE ADDRESS - - PROVIDE 3" MIN INTERIOR DRAIN TILE - - 4" DRAIN TILE EXTERIOR -
---	------	---

**Comments:**