

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20191131
Address: 1420 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------|-------------|----------|-----------------------|
| DE - Fire Line - Flush | Joe Starlin | Passed | Tuesday, May 19, 2020 |

Informational:
1 Misc 5-19-20 2:32pm They flushed the fire line for 4 minutes. The line is approximately 35' long.

Comments: