

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200759
Address: 2417 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Not Ready	Wednesday, May 20, 2020

Corrective Action Required:

1	Misc	- INTERIOR DRAIN TILE CONNECTED TO SUMP BASIN REQUIRED - - EXTERIOR DRAIN TILE- - BACKFILL AROUND FOUNDATION FOR ACCESS -
---	------	---

NOT READY FEE

Comments: