

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Michael Harkins	Partial	Wednesday, May 20, 2020

Corrective Action Required:

1	Misc	Pending engineered soils report.
		Perimeter footing installed, ufer in SW corner. 10 interior piers.

Informational:

2	Misc	2 SPREAD FOOTINGS FRONT OF BUILDING 10 BARS EACH WAY
---	------	--

Comments: