

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183215
Address: 1420 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Failed	Wednesday, February 19, 2020

Corrective Action Required:

1	Misc	G.E.C.s NOT TERMINATED TO GROUND ROD. IN-USE COVERS REQUIRED AT RECEPTACLES.
---	------	---

Comments: