

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20191159  
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Commercial</b>	Robb Popp	Partial	Thursday, May 21, 2020

Corrective Action Required:

1 Misc

THE FOLLOWING AREAS ARE APPROVED:  
EAST SIDE OF POOL DECK NEXT TO BUILDING WORKING SOUTH EAST.  
SOUTHEAST CORNER OF POOL ENTRANCE  
BONDING FROM POOL AND SOUTHEAST CORNER LIGHT POLE  
BONDING OF POOL LOOP AND 2 SHADE POLES  
BONDING OF REMAINING 3 SOUTH SHADE POLES  
BONDING OF POOL LOOP AND POOL MAT TO SW CORNER  
BONDING OF. POOL LOOP WEST SIDE  
BONDING OF 3 WEST SHADE STRUCTURES  
BONDING OF 2 LIGHT POLES  
BONDING LOWER MAT WEST SIDE

Partial Correction:

2 Misc

NO ISSUES FOUND ON EQUIPOTENTIAL BONDING AT:  
POOL BOTTOM SLAB - LEADS STUBBED UP ABOVE POUR LINE; WEST POOL WALL FROM NORTH ALONG WIDTH OF SURGE TANK; EAST POOL WALL NORTH 25'; WEST POOL WALL; SOUTH EXTREMITY OF POOL SLAB REINFORCING & PLUMBING CASTINGS-  
5/1/20 LIFT, LADDER, SHADE STRUCTURE, DECK

**Comments:**

