

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192572
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Thursday, May 21, 2020

Corrective Action Required:

1	Misc	INSPECTION OF 3RD FLOOR ONLY: -INSTALL RESTROOM SIGNAGES -RECEPTACLES LOCATED WITHIN SIX FT OF THE INSIDE WALL OF THE NURSE STATION SINKS SHALL BE GFCI-PROTECTED
---	------	---

Comments: