

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192670
Address: 920 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Thursday, May 21, 2020

Corrective Action Required:

1	Misc	-pending special inspections report. -label RTU'S -Complete labeling of MDP and other disconnects at rear of building. - GFCI for RTU'S within 25'/
---	------	--

Complete all other departments lists for TCO.

Comments: