

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190679

Address: 222 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mark Harding	Passed	Thursday, May 14, 2020

Informational:

2 Misc

HOLD DOWNS COMPLETE 1ST & 2nd FLOOR

EXTERIOR WALLS

2nd floor offices metal stud framing excluding kitchen & restrooms & office near stairway not complete

1st floor interior shear wall NW & SE walls screw pattern 3" perimeter

12" field to 10' ceiling

Comments: