CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172521

Address: 241 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Michael Harkins Partial Friday, May 22, 2020

Commercial

Corrective Action Required:

1 LOWER LEVEL SOUTH END & NORTH END -

OK TO INSULATE

- CHECK FLASHING UNDER MISSING WINDOWS -

Corrective Action Required:

2 FIRST FLOOR SOUTH END - OK TO INSULATE

NORTH END - OK TO INSULATE

- CHECK FLASHING MISSING WINDOWS -

Corrective Action Required:

3 SECOND FLOOR SOUTH END - OK TO INSULATE

- 307 provide roof boots, -

- 305 roof boots -

NORTH END - OK TO INSULATE

- CHECK FLASHING UNDER MISSING WINDOWS -

Comments: