

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20192572
Address: 1980 SE BLUE PKWY, LEES SUMMIT, MO 64063
Inspected On: Friday, May 22, 2020
Inspected By: Khanh Nguyen
Expiration Date: 6/22/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, May 22, 2020

Corrective Action Required:

1	Misc	-INSTALL RESTROOM SIGNAGES -RECEPTACLES LOCATED WITHIN SIX FT OF THE INSIDE WALL OF THE NURSE STATION SINKS SHALL BE GFCI-PROTECTED -INSTALL BOX EXTENSIONS FOR ALL BOXES RECESSED BEHIND COMBUSTIBLE WALL FINISH AT RECEPTION AREAS -PROVIDE GFCI PROTECTION FOR ALL RECEPTACLES LOCATED WITHIN SIX FT OF SINKS IN RM 1-310, 317, AND 320 -COMPLETE P/T DISCHARGE AND PAN DRAINAGE FOR WATER HEATER IN RM 1-323
---	------	--

****EXAM LIGHTS ABOVE ROOMS 1-208, 1-321, AND 3-219 ARE CURRENTLY NOT INSTALLED BUT WILL BE INSTALLED BY OWNERS.**

