

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20193451  
**Address:** 1405 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed - Stop Work	Tuesday, May 26, 2020

Corrective Action Required  
1 Misc

- TIGHTEN ANCHOR BOLTS GARAGE -
- SEAL PENETRATIONS DEAD SPACE AT MUD ROOM, SEAL AROUND GAP OF FIREBLOCK IN DEAD SPACE -
- SEAL FLOOR PENETRATIONS MUD ROOM BATH -
- PROVIDE SOLID SECURITY BLOCKING PATIO DOOR -
- FIRE BLOCK HVAC CHASES GREAT ROOM -
- FIRE BLOCK CHASE LAUNDRY ROOM -
- FIREBLOCK DEADSPACE 2ND FLOOR BEDROOM N
- SEAL ELECTRICAL PENETRATIONS TOP & BOTTOM PLATES BOTH 2ND STORY BEDROOMS -
- PROVIDE DOUBLE JOIST AT FURNACE PER PLAN -

HOUSE HAS BEEN INSULATED BEFORE ALL ROUGH APPROVAL

5/26 - HOUSE HAS SHEETROCK WITHOUT APPROVAL, REMOVE ALL SHEETROCK FOR INSPECTION - STOP WORK ORDER ISSUED

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

**Comments:**