

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20191897  
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	Ronald Paynter	Failed	Tuesday, May 26, 2020

Corrective Action Required:

1	Misc	Same 2 troubled areas dumped silt into the roadways (the curve on Pergola Park and the corner of Mary and Redbuck). Please clean up the silt and install better erosion control devices. RP 5-26-20
---	------	---

**Comments:**