

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20200304  
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Hydrostatic Test</b>	Joe Starlin	Passed	Tuesday, May 26, 2020

Informational:  
1 Misc 5-26-20 Rodrigues has started the test. The gauge is not certified however Steve Robbins knows the crew and trust the gauge to be accurate. The gauge is new. The water line has passed. 150 for two hours.

**Comments:**