

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20200323

Address: 440 NW CHIPMAN RD, Unit:IR, LEES SUMMIT, MO 64086440 NW CHIPMAN RD, LEES SUMMIT, MO  
64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	Joe Starlin	Partial	Tuesday, May 26, 2020

Informational:

1 Misc

3-13-20 All erosion appears to be compliant at this time.

Informational:

2 Misc

3-17-20 I spoke with the superintendent on site about his SWPPP book and keeping it updated. He assured me he would do so moving forward.

Informational:

3 Misc

3-18-20 The silt fence is in place and working at this time. 4-29-20 8:54am All silt fence is up and appears to be working. 5-26-20 8:39am They have tracked mud out on Ward rd. ESS is cleaning it up now.

**Comments:**