CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191007

Address: 1844 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Patrick Schonfeldt Failed Wednesday, May 27,

Residential 2020

Corrective Action Required:

1 E3802.1 Bathroom - GFCI Protection required at all exterior receptacles

receptacles - All weather cover required at exterior receptacle W side

- Place Sod

- Deck currently being converted for stairs to grade, will need to inspect deck

after all modifications are complete

- Seal around all exterior light fixtures

Comments: