

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20192842  
Address: 116 NW MACKENZIE DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Wednesday, May 27, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- submit as graded plot plan -</li><li>- no footing inspection on record -</li><li>- no deck pier inspection on record -</li><li>- no water service inspection on record -</li><li>- all rough inspection failed -</li><li>- driveway inspection still pending -</li><li>- provide permanent address -</li><li>- provide sod &amp; splash blocks -</li><li>- provide erosion control until sod complete -</li><li>- provide self closing door garage -</li><li>- provide hammer arrestor dishwasher-</li><li>- provide cover plates switches/ receptacles garage -</li><li>- seal exterior light fixtures, top meter can, ac disconnect, gas line at meter -</li><li>- provide deadbolts exterior doors-</li><li>- AFCI breakers won't trip: entry/living, bar, upper ft bedroom, -</li><li>- engineer report retaining wall -</li></ul>
---	------	--

Comments: