

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172531
Address: 257 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Wednesday, May 27, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- G2 replace type X on ceiling with type C -- G3 replace type X on ceiling with type C -- G7 complete screw pattern at bottom plate -- south corridor replace type X on ceiling with type C -- G12 no rock at meter bank -
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: