

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191872
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	John DiMauro	Failed	Thursday, May 28, 2020

Corrective Action Required:

2 Misc

The construction entrances for both The Manor & Reserve at Stoney creek need to be re-established. Silt and mud is running off site and into the storm water collection system.

Make corrections asap.

Comments: