

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192644
Address: 2924 NW AUDUBON LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, May 28, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- provide 3rd party footing inspection -- address rafters landing on blocks single car garage and 2nd story -- provide (6) studs under triple LVL garage behind front door per plan -- provide 2 anchor bolts SCH 40 columns garage -- provide anchor bolt SCH 40 column at patio door -- provide plumbing nail guard master water closet -- seal low volt floor penetration in chase outside bed #4 -
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- address rafters landing on blocks single car garage and 2nd story -- provide (6) studs under triple LVL garage behind front door per plan -- provide 2 anchor bolts SCH 40 columns garage -- provide anchor bolt SCH 40 column at patio door -- provide plumbing nail guard master water closet -- seal low volt floor penetration in chase outside bed #4 -
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: