

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193623
Address: 440 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Michael Harkins	Partial	Thursday, May 28, 2020

Informational:
1 Misc - NEED TO CHECK GAS PIPE SUPPORT ON ROOF POURING RAIN 5/28/20 -
- ABOVE CEILING APPROVED -
Michael Harkins 05/28/2020 1:07 PM

Comments: